

Light Category	Australian standard	Information Source	Perscribed Item	Test / Approval status
<b>Fluoro Tube replacements</b>	AS/NZS60968 & AS/NZ61347-1 clause 14	Energy safe Victoria	no (must confirm)	Testing has been completed against International standard EN60968
<b>Downlights</b>				
<i>Integrated</i>		Energy safe Victoria	Yes, power supply only	approval due to use of approved LED driver (approval NSW23742)
<i>Bulb - 240 Vac</i>	AS/NZS60968 & AS/NZ61347-1 clause 14	Energy safe Victoria	No	Testing has been completed against International standard EN60968
<i>Bulb - 12/24 V DC</i>		Energy safe Victoria	No	testing not required for low voltage bulbs
<b>Replacement Bulbs</b>	AS/NZS60968 & AS/NZ61347-1 clause 14	Energy safe Victoria	No	Testing has been completed against International standard EN60968
<b>Flood Light</b>		Energy safe Victoria	Yes, power supply only	OK when used with approved Power supply
<b>Spot Light</b>		Energy safe Victoria	Yes, power supply only	OK when used with approved Power supply
<b>Ribbon Light</b>		Energy safe Victoria	Yes, power supply only	OK when used with approved Power supply

**Note**

- 1) Nexgen will supply australian approved power supplies
- 2) A perscribed item must be approved by an Australian Government regulator prior to sale